



**BUREAU  
VERITAS  
EGYPT**

**INSPECTION CERTIFICATE  
REF.2001/11/17/71**

The undersigned, acting within the scope of the General Conditions of Services of Bureau Veritas and at the request of International Security & Safety System Co. (ISS), certifies that between the dates of 27/01/2002, 30/01/2002 and 12/02/2002 an examination of the Fire Fighting System installed at El Obour Paints & Chemical Industries (PACHIN) Factory at El Obour City was performed.

\* **Description** : Fire Fighting System Inspection and Test Witnessing.

\* **Drawings** : Site drawings supplied by ISS.

\* **Specification**: NFPA

\* **The scope of this mission covers Inspection & Testing of the following:**

- 1- Fire Pumps.
- 2- Water Based Automatic Sprinkler System.
- 3- Foam Based Automatic Sprinkler System.
- 4- Fire Hydrants And Hose System.
- 5- Inergen System.
- 6- Co2 System.
- 7- Fire Detection System.

\* **Enclosures** : The following documents as hereunder:

- i. Test & Inspection results.
- ii. Welders certificates
- iii. EXD Fire Fighting System in EXD Building.
- iv. Foam "Sample analysis"
- v. Event log report.
- vi. Drawings & Marks for the Tested Items.

In conclusion to this work, we hereby certify that the Fire Fighting System has been inspected, tested and documented in accordance with NFPA requirement and found satisfactory.

**For Bureau Veritas,  
Ahmed Deghedie**

**CBL  
Issued at Egypt on 13/02/2002**